

Certificate of Compliance

Certificate: 1807312

Master Contract: 167082

Project: 1991724

Date Issued: June 24, 2008

Issued to: Grundfos Management A/S
Poul Due Jensen Vej 7
8850 Bjerringbro
Denmark

The products listed below are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US'



Issued by: O. Ewanchyna, P. Eng.

Authorized by: M.H.J. Hoendervangers



PRODUCTS

CLASS 3631 05 - TEST AND MEASUREMENT EQUIPMENT

CLASS 3631 85 - TEST AND MEASUREMENT EQUIPMENT -Certified to US Standards

Differential Pressure Sensor, Model DPI, rated 12-30 Vdc, 0,037 A, permanently connected, maximum ambient 70 °C.

Flow, Relative pressure and Differential Pressure Sensor, Models: RPS, VFS and DPS, rated 5 Vdc, 0,05 A, permanently connected, maximum ambient 70 °C.

APPLICABLE REQUIREMENTS

CAN/CSA-C22.2 No. 61010.1-04 - Safety Requirements for Electrical Equipment for Measurement, Control, and Laboratory Use, Part 1: General Requirements

UL Std. No. 61010-1 (2nd Edition) - Safety Requirements for Electrical Equipment for Measurement, Control, and Laboratory Use - Part 1: General Requirements

The 'C' and 'US' indicators adjacent to the CSA Mark signify that the product has been evaluated to the applicable CSA and ANSI/UL Standards, for use in Canada and the U.S., respectively. This 'US' indicator includes products eligible to bear the 'NRTL' indicator. NRTL, i.e. National Recognized Testing Laboratory, is a designation granted by the U.S. Occupational Safety and Health Administration (OSHA) to laboratories which have been recognized to perform certification to U.S. Standards

Certificate: 1807312

Project: 1991724



Master Contract: 167082

Date Issued: June 24, 2008

APPLICABLE REQUIREMENTS

- | | |
|---|--|
| CAN/CSA-C22.2 No. 61010.1-04 | - Safety Requirements for Electrical Equipment for Measurement, Control, and Laboratory Use, Part 1: General Requirements |
| UL Std. No. 61010-1 (2 nd Edition) | - Safety Requirements for Electrical Equipment for Measurement, Control, and Laboratory Use - Part 1: General Requirements |
| IEC 61010-1 (2 nd Edition) | - Safety Requirements for Electrical Equipment for Measurement, Control, and Laboratory Use - Part 1: General Requirements |

Supplement to Certificate of Compliance

Certificate: 1807312

Master Contract: 167082

*The products listed, including the latest revision described below,
are eligible to be marked in accordance with the referenced Certificate.*

Product Certification History

Project	Date	Description
1991724	June 24, 2008	Report reissued. Addition of models RPS, VFS and DPS
1807312	June 23, 2006	Original Certification of Differential Pressure Sensor, Model DPI